



W4 DOMESTIC SERVICES

TEL - 02392 618866

WEBSITE - WWW.DOMESTIC-SERVICES.CO.UKEMAIL - INFO@DOMESTIC-SERVICES.CO.UK

209319

PLUMBING / HEATING / GAS / ELECTRICS / RENEWABLES / BUILDING WORKS

BOAT - GAS SAFETY INSPECTION CERTIFICATE **GS25008**

BOAT DETAILS:

NAME	ASTARTE - 78991	CONTACT	W4CANALBOATHIRE@GMAIL.COM
ADDRESS	MONKSMEAD MOORINGS, WOOLHAMPTON, KENNET AND AVON CANAL		

OWNER / AGENT DETAILS:

NAME	W4CANALBOATHIRE	CONTACT	W4CANALBOATHIRE@GMAIL.COM
ADDRESS	9 WATERMEAD ROAD, FARLINGTON, PO6 1LL		

WORK DESCRIPTION:

DESCRIPTION OF WORKS	ANNUAL GAS SAFETY INSPECTION
DATE AND TIME OF WORKS	08/03/2026

APPLIANCE DETAILS:

TYPE	GAS BOILER	GAS COOKER	NA	NA	NA
LOCATION	CUPBOARD	KITCHEN - GALLEY	NA	NA	NA
MAKE	ELLIS	BEKO	NA	NA	NA
MODEL	NA	KDG583S	NA	NA	NA
SERIAL NO.	NA	NA	NA	NA	NA
GC NUMBER	NA	NA	NA	NA	NA

FLUE AND VENTILATION DETAILS:

TYPE OF FLUE	OPEN FLUED	FLUELESS	NA	NA	NA
ROUTE / TERM	PASS	NA	NA	NA	NA
FLUE FLOW	PASS	NA	NA	NA	NA
VENTILATION (SIZE AND LOCATION)	PASS	PASS	NA	NA	NA
VISUAL CHECK	PASS	PASS	NA	NA	NA
CATCHMENT	NA	NA	NA	NA	NA

OPERATION DETAILS:

FLAME PICTURE	PASS	PASS	NA	NA	NA
SOOTING	NO SIGN	NO SIGN	NA	NA	NA
OVERHEATING	NO SIGN	NO SIGN	NA	NA	NA
STANDING PRESSURE	NA	NA	NA	NA	NA
WORKING PRESSURE	NA	37 MBAR	NA	NA	NA
GAS PIPE SIZING OK?	PASS	PASS	NA	NA	NA
BURNER PRESSURE	NA	NA	NA	NA	NA
HEAT INPUT	6.7 KW	12.5 KW	NA	NA	NA
SPILLAGE TEST	PASS	NA	NA	NA	NA
FSD DEVICE	PASS	PASS	NA	NA	NA
SAFE TO USE	YES	YES	NA	NA	NA
SERVICE CERT REF:-	NA	NA	NA	NA	NA

GAS CYLINDER AND PIPEWORK CHECKS:

LOCATION OF CYLINDERS	REAR DECK	GAS TIGHTNESS TEST	PASS	ECV - ACCESSIBLE / WORK	PASS
VENTILATION OF STORAGE	PASS	LPG WORKING PRESSURE	37.8 MB	BUBBLE TESTER FITTED	YES - PASS
LOCATION OF STORAGE OK	PASS	LPG LOCKUP PRESSURE	42.2 MB	VISUAL / LABELS FITTED	PASS

REMEDIAL WORK AND / OR FAULTS (INC. WARNING NOTICES):

LOCATION	COMMENTS	WARNING Y/N	REF
NA	NA	NA	NA

DECLARATIONS:

PRINTED	SIGNED	DATED
RUSSELL WARNER		08/04/2026

NOTE: ALL THE ABOVE APPLIANCES HAVE BEEN FULLY SERVICED AS PART OF THIS GAS SAFETY CERTIFICATE AND SERVICE CERTIFICATES MAY WELL HAVE BEEN ISSUED WITH THIS NOTICE (SEE ABOVE REF)

IF REMEDIAL WORK WAS REQUIRED THEN A REMEDIAL NOTICE WILL ALSO BE ATTACHED